





Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Harmer AV outlet with screw thread adaptor (Product Ref: AV300T shown) incorporating clamping ring & domical grate.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.

- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
 White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
 Alumasc Two Layer Cold RBM
 Harmer AV Rainwater Outlet


Drawing No:
 RBM-CT 01 01

Scale:
 Not to Scale

Revision:
 A

Date:
 January 2026

© Copyright reserved




Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Roof-Pro Prodrain refurbishment outlet.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.

- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
 White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
 Alumasc Single Layer Cold RBM
 Prodrain Rainwater Outlet

Drawing No:
 RBM-CT 01 02

Scale:
 Not to Scale

Revision:
 A


Date:
 January 2026

© Copyright reserved


Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Lead chute draining to a new external hopper and downpipe.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.



- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
Alumasc Two Layer Cold RBM
Rainwater Drainage Chute


Drawing No:
RBM-CT 01 03

Scale:
Not to Scale

Revision:
A

Date:
January 2026

© Copyright reserved




Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Treated timber batten approx. 50x25mm, by others.
4. Alumasc cap sheet to form welted drip detail.
5. Alumasc gutter system & downpipe (Product Ref: GX gutter shown), to be installed in accordance with Alumasc fixing instructions.
6. Hardboard former (optional) to welted drip, by others.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.

- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
 White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
 Alumasc Two Layer Cold RBM
 Welted Drip to External Gutter


Drawing No:
 RBM-CT 02 01

Scale:
 Not to Scale

Revision:
 A

Date:
 January 2026

© Copyright reserved




GRP check trim
detail


Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Hardboard former (optional) to welted drip, by others.
4. Alumasc GRP Check Trim.
5. Alumasc Roofing Sealant.


Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.



Welted drip edge detail



- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
Alumasc Two Layer Cold RBM
Check Kerb with GRP Trim/Welted Drip

Drawing No:
RBM-CT 02 02

Scale:
Not to Scale

Revision:
A

Date:
January 2026

© Copyright reserved


Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Alumasc 100x100mm reinforcing strip into the angle.

Detailing:

- (i) Alumasc Termination bar sealed with Alumasc Roofing Sealant.
- (ii) Roof-Pro Proflash (lead alternative) cover flashing, or Code 4/5 lead cover flashing, by others.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.



- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
Alumasc Two Layer Cold RBM
Abutment

Drawing No:
RBM-CT 03 01


Revision:
A

Scale:
Not to Scale

Date:
January 2026

© Copyright reserved


Welted drip edge option




Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Alumasc 100x100mm reinforcing strip into the angle.
4. Alumasc GRP Check Trim.
5. Alumasc Roofing Sealant.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.



- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
Alumasc Two Layer Cold RBM
Box Out Parapet - GRP Trim / Welted Drip

Drawing No:
RBM-CT 03 02

Scale:
Not to Scale

Revision:
A


Date:
January 2026

© Copyright reserved

Section Key:

- 1. Alumasc underlay.
- 2. Alumasc cap sheet.
- 3. Alumasc 100x100mm reinforcing strip into the angle.
- 4. Alumasc non-penetrating coping system (Product Ref: Skyline coping shown), installed in accordance with Alumasc fixing instructions.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.



- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.

- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
Alumasc Two Layer Cold RBM
Box Out Parapet - Metal Capping


Drawing No:
RBM-CT 03 03

Scale:
Not to Scale

Revision:
A

Date:
January 2026

© Copyright reserved




Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Alumasc 100x100mm reinforcing strip into the angle.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.

- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
 White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:

Alumasc Two Layer Cold RBM
 Change in Level


Drawing No:
 RBM-CT 03 04

Scale:
 Not to Scale


Revision:
 A

Date:
 January 2026


© Copyright reserved



Stage 1



Stage 2




Stage 3

Stage 1:
Star cut base layer to form the base of the upstand, apply separate collar to conceal pipe.

Stage 2:
Install cap sheet to form collar around the base layer, star cut at base as detailed.

Stage 3:
Install Stainless Steel jubilee clip to hold seal under compression.



Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Alumasc Roofing Sealant.
4. Stainless steel jubilee clip, by others.
5. Metal apron flashing, by others.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.

- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
 White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
 Alumasc Two Layer Cold RBM
 Cold Pipe Penetration - Felt Collar


Drawing No:
 RBM-CT 04 01

Revision:
 A


Scale:
 Not to Scale

Date:
 January 2026


© Copyright reserved



Stage 1



Stage 2




Stage 3

Stage 1:
Star cut base layer to form the base of the upstand, apply separate collar to conceal pipe.

Stage 2:
Install cap sheet to form collar around the base layer, star cut at base as detailed.

Stage 3:
Install Stainless Steel jubilee clip to hold seal under compression.



Section Key:

1. Pipe sleeve, by others.
2. Alumasc underlay.
3. Alumasc cap sheet.
4. Alumasc Roofing Sealant.
5. Stainless steel jubilee clip, by others.
6. Metal apron flashing, by others.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.

- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
Alumasc Two Layer Cold RBM
Hot Pipe Penetration - Felt Collar


Drawing No:
RBM-CT 04 02

Revision:
A


Scale:
Not to Scale

Date:
January 2026

© Copyright reserved



Option: Alumasc vertical
PVCu kerb on builders kerb




Option: Alumasc kerb
adaptor to builders kerb


Section Key:

1. Alumasc underlay.
2. Alumasc cap sheet.
3. Alumasc splayed PVCu kerb.
4. Alumasc polycarbonate triple skin rooflight, in accordance with Alumasc specification.

Flame-free installation methods and/or materials must be used around any combustible materials which may be encountered. The contractor must enforce a torch-free zone as dictated by their insurers; however, it is recommended that this must be a minimum of 900mm.



- This drawing was prepared to serve as a guideline representing typical detailing conditions and illustrate the correct application of Alumasc products only. It may be necessary to modify this detail in whole or in part in accordance with specific project conditions, design or requirements.
- Refer to the Alumasc project specification for product identification and method of application.



ALUMASC
ROOFING

+44 (0)1744648400
info@alumascroofing.com
www.alumascroofing.com

Alumasc Building Products Ltd
White House Works, Bold Road, Sutton St Helens, Merseyside WA9 4JG

Title:
Alumasc Two Layer Cold RBM
Modular Polycarbonate Rooflight

Drawing No:
RBM-CT 05 01

Revision:
A

Scale:
Not to Scale

Date:
January 2026

© Copyright reserved